

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-1130:100

Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** \*Honeywell International Inc., 1500 W. Dundee Rd., Arlington Heights IL 60004-1472  
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

**DESIGN:** Models SC715C1034, SC715C1042, SC715C1059 chimes and Models SC715D1032, SC715D1040, SC715D1057 and SC715F1003 chime/strobes. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, electrical rating and UL label.

**APPROVAL:** Listed as audible or audible/visual devices for use with separately listed compatible fire alarm control units.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**XLF:** 7135-0785:109

\*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**